

**Office of the Joint Director Fire & Emergency Services
Jammu Range, Jammu**

**The Principal
Army Public School
Dhar Road, Udhampur**

No: JDF&ES/FP/ 5743

Dated: 29.12.2020

Sub: Fire Safety Certificate.

Ref: Your Office letter No.320/Fire Safety/APSDR dated 10.10.2020.

Dear Sir,

The inspection of above said school was got carried out by the inspecting officer of this department. During inspection it was found that the management has installed Fire Alarm and First Aid Fire Extinguishers in their school premises. The school is about 08 Km away from Fire & Emergency Station Udhampur and is 100 meter away from main Dhar Road. Since the school is already functioning as such, the management can proceed ahead for operation subject to adopt the following fire safety precautionary measures in letter and spirit for effective and betterment of the school:-

1. 04 Nos. Clean Agent Type Fire Extinguishers of 02 Kg capacity each should be provided in computer lab.
2. All exists/staircase should be kept open and free from any obstruction for easy and safe evacuation of inmates during any emergency.
3. First Aid Fire fighting system installed in the school building should be checked periodically. Staff and students should be fully trained in handling/ operating of fire fighting system installed in the school building. The management shall intimate the office of Assistant Director, Fire & Emergency Services Command Udhampur - Reasi after each quarter that the fire fighting equipments installed in the school are functioning.
4. No Hazardous material should be kept inside the school premises (especially LPG cylinder, Petrol and Diesel etc.). Any deviation found in this regard, this clearance will be treated withdrawn/cancelled.
5. All class rooms and examination halls having seating capacity for more than 45 students need to be provided with two exits.
6. The corridor of the building shall not be used for any kind of storage.
7. Telephone numbers of nearest Fire & Emergency Stations should be displayed.
8. No addition/alteration should be made by the school management in the existing structure without prior permission from this department. Any deviation found in this regard, this provisional clearance will be treated withdrawn/cancelled.
9. The validity of this clearance shall remain in force for one year and same needs to be renewed after checking of fire fighting system installed in the school (i.e. existing as well as proposed).

Yours sincerely

Joint Director

Fire & Emergency Services

Jammu Range, Jammu